



Bid Number/बोली क्रमांक (बिड संख्या)<sup>:</sup> GEM/2023/B/4049907 Dated/दिनांक : 06-10-2023

# Bid Document/ बिड दस्तावेज़

Rid Dotaile/Fiz Figure		
Bid Details/बिड विवरण		
Bid End Date/Time/बिड बंद होने की तारीख/समय	03-11-2023 16:00:00	
Bid Opening Date/Time/बिंड खुलने की तारीख/समय	03-11-2023 16:30:00	
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	90 (Days)	
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Finance	
Department Name/विभाग का नाम	Department Of Financial Services	
Organisation Name/संगठन का नाम	Uco Bank	
Office Name/कार्यालय का नाम	E	
Total Quantity/कुल मात्रा	4	
Item Category/मद केटेगरी	Online UPS (V2) (Q2)	
Minimum Average Annual Turnover of the bidder (For 3 Years)/बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का)	25 Lakh (s)	
MSE Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से एमएसई छूट	No	
Startup Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से स्टार्टअप छूट	No	
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Experience Criteria, Past Performance, Bidder Turnover, Certificate (Requested in ATC), OEM Authorization Certificate, Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer	
Past Performance/विगत प्रदर्शन	80 %	
Bid to RA enabled/बिंड से रिवर्स नीलामी सक्रिय किया	No	
Type of Bid/बिंड का प्रकार	Two Packet Bid	
Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय	2 Days	

Bid Details/बिड विवरण	
Inspection Required (By Empanelled Inspection Authority / Agencies preregistered with GeM)	
Evaluation Method/मूल्यांकन पद्धति	Total value wise evaluation
Financial Document Required/वितीय दस्तावेज की आवश्यकता है।	Yes

#### EMD Detail/ईएमडी विवरण

Advisory Bank/एडवाईजरी बैंक	State Bank of India
EMD Amount/ईएमडी राशि	30000

#### ePBG Detail/ईपीबीजी विवरण

Required/आवश्यकता	No

- (a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy./जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने है। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।
- (b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable./ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए।

#### Beneficiary/लाभार्थी:

DEPUTY GENERAL MANAGER UCO Bank HO DIT, 3 and 4 DD Block, Sector 1, Saltlake, Kolkata 700064 (M/s Ho Dit)

#### Splitting/विभाजन

Bid splitting not applied./बोली विभाजन लागू नहीं किया गया

- 1. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
- 2. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 80% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU / Public Listed Company. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to

primary product having highest bid value should meet this criterion.

## Pre Bid Detail(s)

Pre-Bid Date and Time	Pre-Bid Venue	
17-10-2023 12:00:00	Pre Bid Meeting link will be done through online mode and link will be shared with interested bidders only. Bidder can send their queries on Banks email @hodit.proc@ucobank.co.in on or before 16-10-2023 4 PM	

# Online UPS (V2) ( 4 pieces )

## Technical Specifications/तकनीकी विशिष्टियाँ

\* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिंड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य	
Generic	Rating in KVA 10.0 KVA		
	Switching Technology	IGBT-PWM	
	Input Voltage	AC Single phase 160V - 260V 50Hz, AC Three phase 300 V - 450V sinewave 50Hz	
	Output Voltage	AC Single phase 230V +/-1% 50 Hz	
	Warranty for UPS (Years)	3, 4, 5 Or higher	
Battery/Backup Bank	Battery/Backup Bank Provided with Online UPS ( Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021)	With Battery	
	Type of Battery (hint: NA in case Battery not provided)	SMF-VRLA conforming to JISC:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest	
	Backup time (Minutes) (hint: NA in case battery not provided)	60 Minutes, 120 Minutes	
	Warranty for battery (Years) by Battery Manufucaturer/Brand hint: NA in case battery not provided	2, 3 Or higher	
Installation and Commissioning or Service	Installation and Commissioning ( Covered in the Scope of Supply)	Provided	

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिंड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य	
	Other Services provided	PAN India service support on 24 x 7 basis, AMC support available warranty, Availability of spares in close proximity (Spares should be easily available close to the site)	
Performance / Inbuilt isolation transformer		With, Without	
Functional	Overall Efficiency (%)	>/=80% & <90% with Inbuilt isolation transformer, >/=90% with Inbuilt isolation transformer, >/=90% & <94% without Inbuilt isolation transformer, >/=94% without Inbuilt isolation transformer	
	Overload limit	20% Overload for minimum 10 minute, 20% Overload for minimum 5 minute, 50% Overload for minimum 1 minute, 50% Overload for minimum 3 seconds	
Accessories	Accessories	Paralleling kit for synchronizing (Parallel Redundant Load Sharing Configuration), Rack for Batteries	
Design / Construction	Type of Design / Construction	Floor Standing, Rack Mountable	

# Consignees/Reporting Officer/परेषिती /रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती / रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Kumar Anup Ranjan	700064,3 &; 4 D D BLOCK, SALT LAKE, KOLKATA	4	90

# **Buyback Detail**

	,	
Item Name	UPS and batteries	
Item Description	2 APLAB & 2 EPOCH make 5 KVA UPSwith 40 Exide make 75 AH batteries, 20 Exide make 65AH batteries	
Serial No.	NONE	
Model	APLAB, EPOCH UPS, EXIDE Batteries	
Brand	APLAB, EPOCH UPS, EXIDE Batteries	
Year of Manufacturing	2013	
Purchase On	2013-08-01	
Age		

Size		
Rating		
Quantity	4	
Unit	APLAB, EPOCH UPS, EXIDE Batteries	
Remark	2 APLAB & 2 EPOCH make 5 KVA UPSwith 40 Exide make 7 AH batteries, 20 Exide make 65AH batteries	
Uploaded Image	View Uploaded Image	

#### Disclaimer/अस्वीकरण

The vendor will be responsible for the un-installation of Buyback items.

# Special terms and conditions-Version:1 effective from 06-07-2022 for category Online UPS (V2)

1. In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS (Version 2.0) with reference to Installation and Commissioning.

Seller's Responsibility: Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.

Buyer's Responsibility: Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.

The above is not applicable for the stores supplied without installation and commisioning.

Note: The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.

# Buyer Added Bid Specific Terms and Conditions/क्रत द्वार

जोडी गई बिड की विशेष शर्तें

## 1. Buyer Added Bid Specific ATC

Buyer uploaded ATC document Click here to view the file.

#### 2. Generic

Buyer Organization specific Integrity Pact shall have to be complied by all bidders. Bidders shall have to upload scanned copy of signed integrity pact as per Buyer organizations policy along with bid. Click here to view the file

# Disclaimer/अस्वीकरण

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. Any clause(s) incorporated by the Buyer regarding following shall be treated as null and void and would not be considered as part of bid:-

- 1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
- 2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
- 3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
- 4. Creating BoQ bid for single item.
- 5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
- 6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
- 7. Floating / creation of work contracts as Custom Bids in Services.
- 8. Seeking sample with bid or approval of samples during bid evaluation process.
- 9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
- 10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
- 11. Creating bid for items from irrelevant categories.
- 12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
- 13. Reference of conditions published on any external site or reference to external documents/clauses.
- 14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

#### This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो।बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।

# ---Thank You/धन्यवाद---